

To Flush a Building:

Go to the point farthest away from where the water enters the building (Main Test Point), find an outside spigot if possible and open that up fully.

Next, work your way back toward where water enters the building, turning on faucets about $\frac{1}{3}$ of the way. Just enough to get some flow but not enough to overwhelm the drainage systems (to avoid flooding).

For any battery-operated faucets, cycle them about 3-5 times or for 1 minute minimum. For the Elkay bottle fillers, a 3-minute minimum flush is required to cycle out the water.

By the time you get through all of the faucets, it should be time to go back to the beginning and start shutting the spigots and faucets off, as long as they've had about 30 minutes of flush time to get fresh water to the outlets.

Let me know if you have any questions

Thank you for choosing to Get the Lead Out.

Bob Franklin

Senior Consultant

Cell: 417-294-6112

bobfranklin@gettheleadoutmo.us



